

Annual Drinking Water Quality Report

Borough of Wharton Water Department

For the Year 2026, Results from the Year 2025

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources.

If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be made by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section #3 of NJ P.L. 2021, c.82 (C.58:12A-12.4 et seq.).

We are committed to ensuring the quality of your water. Our water source is wells. Our three wells draw groundwater from an unconfined Glacial Drift Aquifer Formation. Water from all three wells is chlorinated to provide bacteriological disinfection. In addition, the water from two of the wells is treated through an air stripper unit that targets removal of potential volatile organic compound contamination. Since April 2001, the Wharton Borough Water Department has been purchasing water from the Morris County Municipal Utilities Authority (MCMUA). Their source is ground water, treated with sodium hypochlorite for disinfection and lime for pH adjustment. The MCMUA source water is from two wellfields, Alamatong located in Randolph and Chester Townships consisting of six wells, and Flanders Valley located in Mount Olive and Roxbury Townships with two wells. The MCMUA wells draw their water from the Upper and Lower Stratified Glacier Drift and the Upper and Lower Leithsville Limestone Formations. A source water protection plan that provides more information such as: potential sources of contamination, is available at the MCMUA office at 300 Mendham Road, Morris Township.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Borough of Wharton Water Department Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measure- ment	MC LG	MCL	Likely Source of Contamination
Radiological Contaminants:						
Gross Alpha Test results Yr. 2024	N	Range: 2.29 – 8.19 Highest Detect: 8.19	pCi/l	0	15	Erosion of natural deposits
Inorganic Contaminants:						
Barium Test results Yr. 2024	N	Range = 0.010 – 0.026 Highest detect = 0.026	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test results Yr. 2024	N	Range = 0.87 – 0.98 Highest detect = 0.64	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Test results Yr. 2024 Result at 90 th Percentile	N	0.175 No samples exceeded the action level. 20 samples. Range of detections: 0.011 – 0.279	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2024 Result at 90 th Percentile	N	8.57 1 sample exceeded the action level. Range of detections: ND – 21.2	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel Test results Yr. 2024	N	Range = 0.90 – 1.65 Highest detect = 1.65	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen) Test results Yr. 2025	N	Range = 0.73 – 1.36 Highest detect = 1.36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts:						
TTHM Total trihalomethanes Test results Yr. 2025	N	Range = 1 - 2 Highest detect = 2	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2025	No	Range = 0.5 – 0.8 Highest detect = 0.8	ppb	N/A	60	By-product of drinking water disinfection
PFAS Per- and Polyfluoroalkyl Substances:						
PFOS Perfluorooctane Sulfonic Acid Test results Yr. 2025	N	Range =ND – 3.4 Highest detect = 3.4 Highest average = 2.7	ppt	N/A	13	Used in the manufacture of fluoropolymers
PFOA Perfluorooctane Acid Test results Yr. 2025	N	Range = 2.2 – 4.5 Highest detect = 4.5 Highest average = 3.5	ppt	N/A	14	Used in the manufacture of fluoropolymers
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine Test results Yr. 2025		Range = 0.3 – 0.5 ppm Average = 0.4 ppm		4.0 ppm		4.0 ppm
Secondary Contaminant		Level Detected		Units of Measurement		RUL
Sodium Test results Yr. 2025		Range = 58 – 68		ppm		50

Chlorine: Water additive used to control microbes.

Sodium

We exceeded the Recommended Upper Limit (RUL) for Sodium. For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued a Source Water Assessment Report and Summary for this public water system and the Morris County Municipal Utilities Authority (MCMUA) which is available at <http://www.nj.gov/dep/watersupply/swap/index.html>, or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding your water system's Source Water Assessment and where to obtain MCMUA's Source Water assessment. Wharton Borough and MCMUA's source water susceptibility ratings and a list of potential contaminant sources is included.

Unregulated PFAS Per- and Polyfluoroalkyl Substances / Borough of Wharton PWSID# NJ1439001:						
Contaminant:	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
PFBS Perfluorooctane Acid Test results Yr. 2025	N	Range = ND – 2.2 Highest detect = 2.2 Highest Annual Average = 0.7	ppt	N/A	N/A	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
PFHxS Perfluorohexane Sulfonic Acid Test results Yr. 2025	N	Range = ND – 2.5 Highest detect = 2.5 Highest Annual Average = 0.6	ppt	N/A	N/A	
PFHXA Perfluorohexanoic Acid Test results Yr. 2025	N	Range = ND – 2.2 Highest detect = 2.2 Highest Annual Average = 0.7	ppt	N/A	N/A	

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

The Wharton Borough Water Department and the Morris County MUA routinely monitor contaminants in your drinking water according to Federal and State laws. The tables show the monitoring results for the period of January 1st to December 31st, 2025. We have learned through our monitoring and testing that some contaminants have been detected. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants does not change frequently. Some of our data, though representative, is more than one year old.

Morris County MUA Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Barium Test results Yr. 2023	N	Range = 0.001 – 0.1 Highest detect = 0.1	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test results Yr. 2023	N	Range = ND – 0.8 Highest detect = 0.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride Test results Yr. 2023	N	Range = ND - 0.13 Highest detect = 0.13	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen) Test results Yr. 2025	N	Range = 0.80 – 3.01 Highest detect = 3.01	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nickel Test results Yr. 2023	N	Range = ND – 0.6 Highest detect = 0.6	ppb	N/A	N/A	Erosion of natural deposits
PFAS Per- and Polyfluoroalkyl Substances:						
PFOS Perfluorooctane Sulfonic Acid Test results Yr. 2025	N	Range = ND – 6.21 Highest detect = 6.21 Highest average = 4.96	ppt	N/A	13	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
PFOA Perfluorooctane Acid Test results Yr. 2025	N	Range = 2.36 – 9.21 Highest detect = 9.21 Highest average = 7.67	ppt	N/A	14	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.

Secondary Contaminant	Level Detected	Units of Measurement	RUL
Sodium Test results Yr. 2023	Range = 6 -57	ppm	50

Sodium

The Morris County MUA slightly exceeded the Recommended Upper Limit (RUL) for sodium at one of their wells. For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the RUL may be of concern to individuals on a sodium restricted diet.

What are PFOA and PFOS?

Perfluorooctanoic acid (PFOA) and perfluorooctane sulfonate (PFOS) are per- and polyfluoroalkyl substances (PFAS), previously referred to as perfluorinated compounds, or PFCs, that are man-made and used in industrial and commercial applications. PFOA was used as a processing aid in the manufacture of fluoropolymers used in non-stick cookware and other products, as well as other commercial and industrial uses based on its resistance to harsh chemicals and high temperatures. PFOS is used in metal plating and finishing as well as in various commercial products. PFOS was previously used as a major ingredient in aqueous film forming foams for firefighting and training, and PFOA and PFOS are found in consumer products such as stain resistant coatings for upholstery and carpets, water resistant outdoor clothing, and grease proof food packaging. Although the use of PFOA and PFOS has decreased substantially, contamination is expected to continue indefinitely because these substances are extremely persistent in the environment and are soluble and mobile in water. More information can be found at: [https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOA-websites-OLA%204-24-19SDM-\(003\).pdf](https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOA-websites-OLA%204-24-19SDM-(003).pdf)

Waivers: The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system and MCMUA received monitoring waivers for asbestos and synthetic organic chemicals.

If you have any questions about this report or concerning your water utility, please contact Thomas Quillinan, Director of Public Works at (862) 397-2759. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Council meetings at Borough Hall 10 Robert Street. Meetings are held on the second and fourth Monday of each month at 7:30 p.m., however you may wish to call the Borough or check the meeting schedule calendar at the Borough Hall to confirm a particular date.

Educational Information: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals which can be naturally occurring, or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

DEFINITIONS

In the "Test Results" tables you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or nanogram per liter - one part per trillion corresponds to one minute in 20,000 years, or a single penny in \$100,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Recommended Upper Limit (RUL) - Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste, or appearance. RULs are recommendations, not mandates.

Secondary Contaminant- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Sources of Lead in Drinking Water

The Borough of Wharton Water Department and the Morris County MUA are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as "lead-free", may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as "lead free". However, prior to January 4, 2014, "lead free" allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures.

Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

Steps You Can Take to Reduce Exposure to Lead in Drinking Water

For a full list of steps visit: <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>

Run the cold water to flush out lead. Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain. Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

Use cold, flushed water for cooking and preparing baby formula. Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

Do not boil water to remove lead. Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or most clothes.

Use alternative sources or treatment of water. You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or www.nsf.org for information on performance standards for water filters.

Determine if you have interior lead plumbing or solder. If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

Replace plumbing fixtures and service lines containing lead. Replace brass faucets, fittings, and valves that do not meet the current definition of "lead free" from 2014 (as explained above). Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures.

Remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen.

Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

Test your water for lead. Please call 973-366-2155 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

Get your child tested. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

Have an electrician check your wiring. If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

Water softeners and reverse osmosis units will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

Health Effects of Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Borough of Wharton Water Department is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, call Thomas Quillinan, Director of Public Works at (862) 397-2759 for information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, the Wharton Borough Water Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served by a lead service line*. Our service line inventory is available upon request.

Borough of Wharton Water Department- PWSID # NJ1439001

The Borough of Wharton Water Department is a public community water system consisting of 3 wells

This system's source water comes from the following aquifer: Glacial Sand and Gravel Aquifer System

This system can purchase water from the following water system: Dover Water Department

Susceptibility Ratings for Borough of Wharton Water Department Sources

The tables below illustrate the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors				
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L		
Wells - 3		3		3				1	2	3				3			1	2		1	2			3		

Susceptibility Ratings for Morris County MUA Sources

The following is a brief summary of our source water assessment performed by the NJDEP. Morris County MUA is a public community water system consisting of 8 wells. This system's source water comes from the following aquifers: glacial sand and gravel, limestone. The table below illustrates the susceptibility ratings on the following potential contaminant sources that the NJDEP found within the source water assessment areas. Each source has a susceptibility rating of high, medium, or low for each potential contaminant.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 8		8		4	2	2		2	6	2		6		1	7	1	6	1	2	6		5	3	

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information: go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

Special Notice:

Our water system recently violated a drinking water requirement. Although this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

What Happened? We are required to submit an annual Consumer Confidence Report (CCR) to the New Jersey Department of Environmental Protection (NJDEP) by July 1st of each year. For the 2025 reporting period, we inadvertently submitted the report to the NJDEP late and received a violation (#21047).

What should I do? There is nothing you need to do at this time. This was a reporting violation and it does not impact the quality or safety of your drinking water."

What is being done? Since then, we submitted the required documentation and our system returned to compliance on September 25, 2025. To prevent this from happening again, we have updated our internal administrative calendar and compliance tracking systems to ensure all future annual reports are submitted well in advance of the July 1st deadline.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Availability of Unregulated Contaminant Monitoring Data for the Borough of Wharton Water Department

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available. If you are interested in examining the results* please contact Thomas Quillinan, Director of Public Works at (862) 397-2759.

This notice is being sent to you by the Borough of Wharton Water Department - PWSID# NJ1439001